

Step Test with GPRS in Arnand, Veolia Eau

Case Study CS4 -XS-044-1.0

Introduction

Localising leakage in the network by means of closing valves to quantify the volume of water loss by sector is particularly effective; especially in municipalities with PVC pipes. A good example of this technique was used with Veolia Eau, in the town of Arnand, close to Lake Annecy in Eastern France, on 20th June 2013 using **XStream**.



Implementation


- Define and prepare the areas and sector valves to be closed.
- The **XStream** was connected to the outlet flowmeter on the tank.
It is essential to have a high flowmeter pulse-rate (preferably 1 litre/pulse) to obtain high resolution flowrate changes. In this test the pulse-rate was 10 litre/pulse such that the minimum value was used after each closing.
- A pressure connection could not be made due to no available hydraulic connection.
- Closing the sector valves commences.



The tank supplying the sectorised network.




Despite no GSM signal (phone had no connection) using GPRS 100% of data uploaded by the XStream



The network was divided into nine sectors prior to commencement of the step-test.

Results

Real-time display of data is available on PC, tablet or Smartphone devices equipped with a GPRS connection. Data access is secure and displayed continuously.



The test commenced at 00.40. The graphical results are shown above; blue curve is flow (m³/hour) and red curve is pressure (not used in this test). Comments are added with the "create comment" button. Opening a valve is in green using the "valve open" button and closing in red "shut valve."

Summary

The area had a high flowrate of 22 m³/hour at the beginning of the test. Significant drops in flowrate occurred as follows;

- Valve shut 1: 7 m³/hour
- Valve shut 3: 5 m³/hour
- Valve shut 7: 2.4 m³/hour
- Valve shut 8: 4.8 m³/hour (leakage in PVC sector)
- Valve shut 9: 2.4 m³/hour (leakage directly identified)

Other valve shuts resulted in insignificant flow reductions and no further leakage location surveys in these sectors.



The leak identified at valve shut 9.

This exercise demonstrated successfully;

- Reliable operation despite a low GSM coverage
- Remote data visualization
- Real time flow data at valve closures
- Avoids the need for a person at the flowmeter and any miscalculations
- Avoid a test on the network of 34 km, reduced to only 2.5 km to carry out further investigation
- Leakage identified in an area of PVC pipes where acoustic leak detection difficult
- Check test made no network changes by ensuring flow returns to original value when valves open

Primayer Limited

Primayer House, Parklands Business Park, Denmead, Hampshire, PO7 6XP, United Kingdom

T +44 (0)23 9225 2228 F +44 (0)23 9225 2235

sales@primayer.co.uk www.primayer.com

Registered in England No. 2959100 at above address

